

2025 Water Quality Report

Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúscalo o hable con alguien que lo entienda bien.

Is my water safe?

Last year, your tap water met all U. S. Environmental Protection Agency (EPA) and state drinking water standards. Sandia Peak Utility vigilantly safeguards its water supplies and we would like to report that our system did not violate any drinking water standard or maximum contaminant level in 2025.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders. Some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water is supplied to us from three deep wells (over 600 feet deep) located in the Northeast Heights. Our water is of excellent quality and as of this year, has shown no significant signs in the reduction of flow or volume.

Source water assessment and its availability:

A source water assessment was completed in 2002 and is available upon request by contacting Sandia Peak Utility or the State of New Mexico Environmental Department. Copies may also be requested by emailing the Drinking Water Bureau at drinking.water@env.nm.gov or by calling (505) 476-8620 or 1-877-654-8720. Please include your name, address, telephone number and email address and the name of the Water System. NMED-DWB may charge a nominal fee for paper copies. In conclusion, the Sandia Peak Utility Company water system is well maintained and operated, and sources of drinking water are generally protected from potential sources of contamination based on well construction, hydrogeologic settings, and system operations and management. The susceptibility rank of the entire water system is Moderately High. Although throughout the United States it is common to find potential sources of contamination located atop wellheads, continued regulatory oversight, wellhead protection plans, and other planning efforts continue to be primary methods of protecting and ensuring high quality drinking water.

Why are there contaminants in my drinking water?

Drinking water—whether from the tap or bottled—may contain small amounts of contaminants. This is generally not a cause for concern and does not necessarily mean the water poses a health risk. For more information about contaminants and their potential health effects, contact the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline at 800-426-4791.

Sources of drinking water include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water moves across land or filters through the ground, it can absorb naturally occurring minerals, radioactive materials, and substances from human or animal activity.

Contaminants may include:

Microbial contaminants such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock operations, and wildlife.

Inorganic contaminants like salts and metals, which can occur naturally or result from urban runoff, industrial discharges, oil and gas production, mining, or farming.

Pesticides and herbicides from agricultural use, urban runoff, and septic systems.

Radioactive contaminants from natural sources or from oil and gas production and mining activities.

To ensure tap water safety, the EPA sets regulations limiting the levels of certain contaminants in public water systems. The FDA establishes similar standards for bottled water to protect public health.

About Sandia Peak Utility Company

Sandia Peak Utility Company was established in 1966 and our mission has always been to provide high quality drinking water and superior customer service. We currently provide water to approximately 7,500 people in the Sandia Heights and Primrose Pointe subdivisions in the Northeast Heights.

In partnership with



To support water conservation

Status of water in New Mexico and call for conservation

Water is New Mexico's most precious and natural resource. New Mexico has experienced several consecutive years of drought and meteorologists predict that it will continue. Water conservation is especially important during times of drought. Additionally and arguably more critical, most aquifers in the state are being depleted. Decreasing water levels in aquifers and surface sources can increase the concentration of minerals and contaminants in the drinking water supply.

We at **Sandia Peak Utility** are committed to providing a safe and consistent supply of water and we ask for your help. There are a lot of simple ways to reduce the amount of water used both inside and outside the home. Please conserve water whenever possible by taking the following steps:

- ◆ Know your water supply provider and follow existing water restrictions.
- ◆ Stop leaks. Toilets are the largest water user inside the home. Over time, toilet flappers can decay or minerals can build up on it. It's usually best to replace the whole rubber flapper—a relatively easy, inexpensive do-it-yourself project that pays for itself quickly. You can get instructions for testing for leaks with dye tabs from the Office of the State Engineer's District Offices or call 1-800-WATERNM.
- ◆ Check outdoor fixtures (swamp coolers, irrigation systems, etc) for leaks and repair any leaks.
- ◆ Consider turning the swamp cooler off when away from home or install a thermostat.
- ◆ Minimize evaporation by watering during the early morning hours, when temperatures are cooler and winds are lighter. Make sure irrigation systems are working properly (and you are not watering the house, sidewalk or street) and use only the minimum amount of water needed by plants.
- ◆ Run water only when using it. Turn water off while brushing teeth, shaving, and/or washing counters.
- ◆ Wash only full loads of laundry. Install a water efficient clothes washer (and save 16 gallons per load).
- ◆ Try to shorten showers to 5 minutes.
- ◆ Flush toilets only when necessary. When upgrading or replacing household fixtures, install low-flow toilets, showerheads, washing machines, and faucets.



If you have questions regarding this report, please contact Mitch White at 505-856-6345 or via email at mwhite@sandiapeak.com.



2025 Annual Water Quality Report



Drinking Water Testing



Your drinking water is monitored for many regulated and unregulated contaminants, including pesticides and radioactive contaminants. All monitoring data in this report are from 2025. If a health-related contaminant is not listed in this report, it was not detected in your drinking water.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: NMED or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

Unit Descriptions	
Term	Definition
ug/L	ug/L : Number of micrograms of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (ug/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with customer owned service lines and home plumbing. Sandia Peak Utility Company is responsible for providing high quality drinking water to customer's water meter, but cannot control the variety of materials used in customer owned plumbing components. When your water has been sitting for several hours, you can reduce the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Sandia Peak Utility is required to submit an annual lead line inventory to NMED - Drinking Water Bureau. The most recent inventory was submitted in December 2025. Our investigations have not identified ANY lead service lines in our area. In addition, the Utility is required to collect lead samples from our water system every three years and historically we have never had an issue with lead contaminants. As of this notification, the material type of the service line connected to your meter has been classified as either: Unknown or Non-Lead. As part of our most recent inventory, the system includes a total of 2558 service lines, consisting of 533 non-lead, 0 lead, and 2025 unknown lines. Importantly, the utility-owned portion of all 2,558 service lines have been verified as non-lead.

If you would like to know the classification of your service line, please contact our Customer Service Department at customerservice@sandiapeak.com.

Water Quality Data Table

Unless otherwise noted, the table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range Low	High	Sample Date	Violation	Typical Source
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (as Cl2) (ppm)	4	4	0.7	0.43	0.7	2025	No	Water additive used to control microbes.
TTHMs [Total Trihalomethanes] (ppb)	NA	80	2.23	0	2.23	2025	No	By-product of drinking water disinfection.
HAA5s [Haloacetic Acids] (ppb)	NA	60	ND	0	ND	2025	No	By-product of drinking water disinfection
Inorganic Contaminants								
Barium (ppm)	2	2	.056	NA	.NA	2023	No	Erosion of natural deposits; Discharge of drilling wastes; Discharge from metal refineries
Fluoride (ppm)	4	4	0.77	NA	NA	2023	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen] (ppm)	10	10	1.31	NA	NA	2025	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Radioactive Contaminants								
Uranium (ug/L)	0	30	3	NA	NA	2023	No	Erosion of natural deposits.
Alpha Emitters (pCi/L)	0	15	1.2	NA	NA	2023	No	Erosion of natural deposits.
Radium (combined 226/228) (pCi/L)	0	5	0.64	NA	NA	2023	No	Erosion of natural deposits.

Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
Inorganic Contaminants							
Copper - action level at consumer taps (ppm)	1.3	1.3	0.22	2023	0	No	Corrosion of household plumbing systems; Erosion of natural deposits.
Lead-action level at consumer taps (ppb)	0	15	2.1	2023	0	No	Corrosion of household plumbing systems; Erosion of natural deposits.
Range							
Copper	Low 0.49 ppm			High 0.033 ppm			
Lead	Low 0 ppb			High 2.9 ppb			

Unregulated Contaminants

Certain substances present in drinking water are not regulated by the EPA; however, testing for some of these is required for research purposes under the Unregulated Contaminant Monitoring Rule (UCMR)

Other Water Quality Constituents					
Substance	Your Water	Minimum Reporting Level	Range of Results Low	High	Sample Date
Lithium	15 PPB	10 PPB	15 PPB	15 PPB	2024
Perfluorobutanesulfonic acid	ND	1.8 PPT	<.000003 PPT	<.000003 PP	2024
Perfluoroheptanoic acid	ND	1.8 PPT	<.000003 PPT	<.000003 PPT	2024
Perfluorohexanesulfonic acid	ND	1.7 PPT	<.000003 PPT	<.000003 PPT	2024
Perfluorononanoic acid	ND	1.8 PPT	<.000004 PPT	<.000004 PPT	2024
Perfluorooctanesulfonic acid	ND	1.7 PPT	<.000004 PPT	<.000004 PPT	2024
Perfluorooctanoic acid	ND	1.8 PPT	<.000004 PPT	<.000004 PPT	2024
Perfluorodecanoic acid	ND	1.8 PPT	<.000003 PPT	<.000003 PPT	2024
Perfluorododecanoic acid	ND	1.8 PPT	<.000003 PPT	<.000003 PPT	2024
Perfluorohexanoic acid	ND	1.8 PPT	<.000003 PPT	<.000003 PPT	2024
Perfluoroundecanoic acid	ND	1.8 PPT	<.000002 PPT	<.000002 PPT	2024
11-Chloroperfluoro-3-oxaundecane sulfonic acid	ND	1.7 PPT	<.000005 PPT	<.000005 PPT	2024
9-Chloroperfluoro-3-oxanonane sulfonic acid	ND	1.7 PPT	<.000002 PPT	<.000002 PPT	2024
4,8-Dioxa-3H-perfluorononanoic acid	ND	1.7 PPT	<.000003 PPT	<.000003 PPT	2024
Hexafluoropropylene oxide dimer acid	ND	1.8 PPT	<.000005 PPT	<.000005 PPT	2024
Perfluorobutanoic acid	ND	1.8 PPT	<.000005 PPT	<.000005 PPT	2024
6:2 Fluorotelomer sulfonic acid	ND	1.7 PPT	<.000005 PPT	<.000005 PPT	2024
4:2 Fluorotelomer sulfonic acid	ND	1.7 PPT	<.000003 PPT	<.000003 PPT	2024
8:2 Fluorotelomer sulfonic acid	ND	1.7 PPT	<.000005 PPT	<.000005 PPT	2024
Perfluoromethoxypropanoic acid	ND	1.8 PPT	<.000004 PPT	<.000004 PPT	2024
Perfluoropentanoic acid	ND	1.8 PPT	<.000003 PPT	<.000003 PPT	2024
Perfluoromethoxybutanoic acid	ND	1.8 PPT	<.000003 PPT	<.000003 PPT	2024
Perfluoroethoxyethanesulfonic acid	ND	1.6 PPT	<.000003 PPT	<.000003 PPT	2024
Nonafluorodecanoic acid	ND	1.8 PPT	<.00002 PPT	<.00002 PPT	2024
Perfluoropentanesulfonic acid	ND	1.7 PPT	<.000004 PPT	<.000004 PPT	2024
Perfluoroheptanesulfonic acid	ND	1.7 PPT	<.000003 PPT	<.000003 PPT	2024
Perfluorotetradecanoic acid	ND	1.8 PPT	<.000008 PPT	<.000008 PPT	2024
Perfluorotridecanoic acid	ND	1.8 PPT	<.000007 PPT	<.000007 PPT	2024
N-Ethylperfluorooctane sulfon-amidoacetic acid	ND	1.8 PPT	<.000005 PPT	<.000005 PPT	2024
N-Methylperfluorooctane sulfon-amidoacetic acid	ND	1.8 PPT	<.000006 PPT	<.000006 PPT	2024

Other Water Quality Constituents					
Contaminants	Your Water	Units		Your Water	Units
Alkalinity	144	mg/L			
Bicarbonate	175	mg/L			
Calcium	48	mg/L			
Hardness	142	mg/L	Or	8.304	Grains/Gallon
Chloride	ND	mg/L			